

MEADOWLAND ACRES SERVICE AREA NORTH KOOTENAI WATER DISTRICT DRINKING WATER QUALITY REPORT 2016

We are pleased to provide you with this year's Annual Water Quality Report also known by the federal acronym CCR (Consumer Confidence Report). We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is, and always has been, to provide to you a safe and dependable supply of drinking water. The well that serves your area is on Gallop Lane and draws water from the Rathdrum Prairie Aquifer. Your drinking water is safe and meets federal and state requirements.

Our drinking water is safe and meets federal and state requirements. If you have any questions about this report or concerning your water utility, please contact Mike Galante, District Manager at (208) 687-6593. If you want to learn more, please attend any of our regularly scheduled Board meetings that are held at 12:30 PM on the first and third Thursday of each month at the District office: 13649 N Meyer Rd, Rathdrum, Idaho.

North Kootenai Water District monitors for contaminants in your drinking water according to Federal and State laws. The table below shows any detection of contaminants over the past five years. We are pleased to notify you that our water has not exceeded any allowable detection levels. As water travels over the land or underground it can pick up contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In the following table you will find some terms and abbreviations that you may not be familiar with. To help you better understand these terms we provide the following definitions:

Action Level - The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Non-Detects (ND) - Laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Variations & Exemptions (V&E) - State or Federal Environmental Protection Agency (EPA) permission not to meet a MCL or a treatment technique under certain conditions.

Inorganic Contaminants	MCL	MCLG	Our Water	Range of Detection	Sample Date	Violation?	Typical Source of Contaminant
Nitrate	10 ppm	10 ppm	0.375 & 0.366 ppm	N/A	03/16 & 07/16	No	Runoff from fertilizer use, leaching from septic tanks, erosion of natural deposits.

Disinfectants	MCL	MCLG	Our Water	Range of Detection	Sample Date	Violation?	Typical Source of Contaminant
Sodium Hypochlorite	4 ppm	4 ppm	0.12 ppm	0.25-0.47 ppm	2016	No	Disinfection of distribution components.

Lead and Copper	Action Level	MCLG	Our Water	Range of Detection	Sample Date	Violation?	Typical Source of Contaminant
Lead	15 ppb	15 ppb	2.00 ppb	N/A	08/16	No	Leaching of minerals from plumbing components.
Copper	1.3 ppm	1.3 ppm	0.098 ppm	N/A	08/16	No	Leaching of minerals from plumbing components.

Lead – If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. North Kootenai Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The Federal Environmental Protection Agency (EPA) and U.S. Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

Our wells are within the Rathdrum Prairie Aquifer Wellhead Protection Area. This is a geographical and geological area where strict regulations to protect ground water (drinking water) are applied.

North Kootenai Water District works diligently to provide quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PLEASE DON'T DUMP ANYTHING ON THE GROUND THAT YOU WOULD NOT WANT TO DRINK!